

**MSDH BUREAU OF PUBLIC WATER SUPPLY  
LEAD/COPPER 90TH PERCENTILE**

<b>PWS ID</b>	MS0530012	<b>RESULT TYPE</b>	PB90/CU90
<b>SYSTEM NAME</b>	MS STATE UNIVERSITY	<b>SAMPLE POINT</b>	DS000
<b>COUNTY</b>	OKTIBBEHA		

	<b>Lead 90th</b>	<b># Samples</b>	<b>Copper 90th</b>	<b># Samples</b>
01/01/2014-12/31/2016 (Triennial)	0.005 mg/L	30	0.3 mg/L	30
Action Level	0.015 mg/L		1.3 mg/L	

\* = Action Level Exceeded