

**MSDH BUREAU OF PUBLIC WATER SUPPLY
LEAD/COPPER 90TH PERCENTILE**

PWS ID	MS0530012	RESULT TYPE	PB90/CU90
SYSTEM NAME	MS STATE UNIVERSITY	SAMPLE POINT	DS000
COUNTY	OKTIBBEHA		

	Lead 90th	# Samples	Copper 90th	# Samples
01/01/2019-12/31/2021 (Triennial)	0.003 mg/L	30	0.0 mg/L	30
Action Level	0.015 mg/L		1.3 mg/L	

* = Action Level Exceeded